



TITLE		NOTE: All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.
PW305.INS.AG		
DRAWN BY	DATE	
C.MORRIS	06/12/2017	
CUSTOMER		
CUSTOMER		

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED	A4
--	----

DESCRIPTION:	PW305 one piece cold water storage tank suitable for AG/AF Air gap
ALL DIMENSIONS IN MM - DO NOT SCALE	

DATE	VERSION	NOTES
05/10/2017	A	FIRST ISSUE

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	500 x 500 x 1220mm
EXTERNAL DIMENSIONS	690 x 690 x 1229mm
NOM. CAPACITY	305 Litres
DRY WEIGHT	20 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP



SCALE:1:20 SHEET 1 OF 1