


TITLE		NOTE:		DESCRIPTION:		DATE		VERSION		NOTES		TANK SPECIFICATION :			
PW750.INS.AG		All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.		PW750 one piece cold water storage tank suitable for AG/AF Air gap		09/10/2017		A		FIRST ISSUE		INTERNAL DIMENSIONS 1500 x 1000 x 500mm			
DRAWN BY C.MORRIS		DATE 06/12/2017										EXTERNAL DIMENSIONS 1702 x 1202 x 536mm			
CUSTOMER		CUSTOMER		ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED		A4		ALL DIMENSIONS IN MM - DO NOT SCALE				NOM. CAPACITY 750 Litres			
												DRY WEIGHT 43 KG			
												INSULATION THICKNESS 25mm			
												WRAS CERT. NUMBER 131006			
												MATERIAL GRP			
														SCALE: 1:20	
														SHEET 1 OF 1	