



TITLE  
**PW454.INS-2.AG**

DRAWN BY **C.MORRIS** DATE **07/12/2017**

CUSTOMER  
**CUSTOMER**

**NOTE:**

All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm  
UNLESS OTHERWISE STATED

**A4**

**DESCRIPTION:**

PW340-2 piece cold water storage tank  
suitable for AG/AF Air gap

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE	VERSION	NOTES
18/09/2017	A	FIRST ISSUE

**TANK SPECIFICATION :**

INTERNAL DIMENSIONS	1067 x 610 x 710mm
EXTERNAL DIMENSIONS	1255 x 805 x 749mm
NOM. CAPACITY	454 Litres
DRY WEIGHT	30 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP

**tanks.ie**

SCALE:1:15

SHEET 1 OF 1