



TITLE
PW500.INS-2.AG

DRAWN BY C.MORRIS DATE 07/12/2017

CUSTOMER
CUSTOMER

NOTE:
All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm
UNLESS OTHERWISE STATED

A4

DESCRIPTION:
PW500-2 piece cold water storage tank
suitable for AG/AF Air gap

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE	VERSION	NOTES
05/10/2017	A	FIRST ISSUE

TANK SPECIFICATION :

INTERNAL DIMENSIONS	1000 x 1000 x 500mm
EXTERNAL DIMENSIONS	1180 x 1180 x 536mm
NOM. CAPACITY	500 Litres
DRY WEIGHT	28 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	131006
MATERIAL	GRP

tanks.ie

SCALE:1:20

SHEET 1 OF 1